



TANK 1 - 10,738 LITRES

TANK 2 - 19,062 LITRES

TANK 3 - 10,738 LITRES

▶▶ HOLD DOWN STRAP LOCATION

\* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		FIBRETANK SYSTEMS Pty Limited	
DOMES	100NB	SOCKET	100NB BSP SOCKET
17-19	100NB	SOCKET	100NB BSP SOCKET
18	100NB	DUPLEX	2 x 100NB BSP SOCKET
9	100NB	DUPLEX	2 x 100NB BSP SOCKET
8-11-12	100NB	SOCKET	100NB BSP SOCKET
2	100NB	DUPLEX	2 x 100NB BSP SOCKET
1-3	100NB	SOCKET	100NB BSP SOCKET
DOMES	100NB	SOCKET	100NB BSP SOCKET
FLAT No.	SIZE	ITEM	
DRAWN: V.B.B.		App. Weight:	1,246 kg
DATE: 18-09-01		App. Capacity:	40,472 L
DESCRIPTION		Type	Notes
Construction		TYPE 40	- Tie-Down Straps to suit this tank are part no.
SINGLE WALL		TRIPLE	- Dedmen to suit this tank are part no.
Type		10/20/10	- UNO, all sockets are BSP and are c/w striker plates under.
Compartment Configuration		DRAWING NUMBER:	Revision Details
FH 04 0000-000			No Original Issue
REVISION:			By Date
A			

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
 PO BOX 102  
 CARRINGTON, NSW 2294  
 Ph:(02)4961-2745 Fax:(02)4962-2812