



TANK 1 VOLUME = 26,168 L

TANK 2 VOLUME = 19,668 L

▶▶ HOLD DOWN STRAP LOCATION

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details		
FLAT No.	SIZE	ITEM		No	Revision	By	Date	
21	100NB	SOCKET	FIBRETANK SYSTEMS Pty Limited					
20	100NB	SOCKET						
19	100NB	SOCKET						
17 - 18	100NB	SOCKET						
15	100NB	SOCKET						
11	100NB	SOCKET						
7 - 8	100NB	SOCKET						
3 - 4 - 5	100NB	SOCKET		- Tie-Down Straps to suit this tank are part no.	C	SOCKET ADDED TO FLAT 5 AND 8	V.B.B.	9-5-02
2	100NB	SOCKET		- Dedmen to suit this tank are part no.	B	SOCKET ADDED TO FLAT 4 AND 18	V.B.B.	14/3/02
1	100NB	SOCKET		- UNO, all sockets are BSP and are c/w striker plates under.	A	Original Issue	-	-
				Revision Details				
				No				

DRAWN: V.B.B.	App. Weight: 1,550 kg	Construction Type	DOUBLE 25/20	DRAWING NUMBER:	FG 045000-000	REVISION:	C
DATE: 31-07-01	App. Capacity: 44,048 L	SINGLE WALL TYPE 45	DOUBLE 25/20	Compartment Configuration			

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON, NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812