



▶▶ HOLD DOWN STRAP LOCATION \* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM		No	Revision	By	Date
21	100NB	SOCKET	100NB BSP SOCKET	B	SOCKET ADDED TO FLAT 1	V.B.B.	14/3/02
20	100NB	SOCKET	100NB BSP SOCKET	A	Original Issue	-	-
19	100NB	SOCKET	100NB BSP SOCKET				
12	100NB	SOCKET	100NB BSP SOCKET				
2	100NB	SOCKET	100NB BSP SOCKET				
1	100NB	SOCKET	100NB BSP SOCKET				

DRAWN: V.B.B.		App. Weight: 1,405		Construction Type		DRAWING NUMBER:					
DATE: 11-07-01		App. Capacity: 44,048		SINGLE WALL TYPE 45		FS 045000-000					
<p>The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes &amp; fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested &amp; installed as per current specifications and instructions.</p>				<p>All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.</p>				<p>THIS DRAWING &amp; THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL &amp; MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF STP GROUP PTY LTD</p>			
				<p>FIBRETANK SYSTEMS Pty Limited PO BOX 102 CARRINGTON., NSW 2294 Ph:(02)4961-2745 Fax:(02)4962-2812</p>							