



TANK 1 VOLUME = 14,304 L

TANK 3 VOLUME = 22,638 L

TANK 3 VOLUME = 14,304 L

▶▶ HOLD DOWN STRAP LOCATION * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
DOME	100NB	SOCKET	100NB BSP SOCKET			No	By
24	100NB	DUPLEX	2 x 100NB BSP SOCKET				
21-22-23-25	100NB	SOCKET	100NB BSP SOCKET				
17-18	100NB	MONITOR	100NB BSP SOCKET INTERSTICE MONITOR (DUAL BULKHEAD)				
14	100NB	DUPLEX	2 x 100NB BSP SOCKET				
10-12-12-16	100NB	SOCKET	100NB BSP SOCKET				
8-9	100NB	MONITOR	100NB BSP SOCKET INTERSTICE MONITOR (DUAL BULKHEAD)				
2	100NB	DUPLEX	2 x 100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.			
1-3-4-5	100NB	SOCKET	100NB BSP SOCKET	- Dedmen to suit this tank are part no.			
DOME	100NB	SOCKET	100NB BSP SOCKET	- UNQ, all sockets are BSP and are c/w striker plates under.			
FLAT No.	SIZE	ITEM					
DRAWN: V.B.B.		App. Weight:	1,962 kg	Construction		Type	
DATE: 8-7-03		App. Capacity:	51,200 L	SINGLE WALL		TYPE 50	
				Compartment Configuration		TRIPLE 15-20-15	
				Notes		DRAWING NUMBER: FH 050000-001	
				Revision Details		REVISION: A	

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON, NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812