



TANK 1 VOLUME = 31,532 L

TANK 2 VOLUME = 19,668 L

▶▶ HOLD DOWN STRAP LOCATION

\* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM		No	Original Issue	By	Date
25	100NB	SOCKET	100NB BSP SOCKET				
24	100NB	SOCKET	100NB BSP SOCKET				
23	100NB	SOCKET	100NB BSP SOCKET				
21	100NB	SOCKET	100NB BSP SOCKET				
18	100NB	SOCKET	100NB BSP SOCKET				
14	100NB	SOCKET	100NB BSP SOCKET				
6	100NB	SOCKET	100NB BSP SOCKET				
3	100NB	SOCKET	100NB BSP SOCKET				
2	100NB	SOCKET	100NB BSP SOCKET				
1	100NB	SOCKET	100NB BSP SOCKET	A	Original Issue		

  

DRAWN: V.B.B.	App. Weight: 1,762 kg	Construction Type	DOUBLE 30/20	DRAWING NUMBER:	FG 050000-000	REVISION:	A
DATE: 31-07-01	App. Capacity: 51,200 L	TYPE 50	DOUBLE	COMPARTMENT CONFIGURATION			

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
 PO BOX 102  
 CARRINGTON, NSW 2294  
 Ph:(02)4961-2745 Fax:(02)4962-2812