



FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

▶▶ HOLD DOWN STRAP LOCATION

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM		No	By	Date	
25	100NB	SOCKET	100NB BSP SOCKET				
24	100NB	SOCKET	100NB BSP SOCKET				
23	100NB	SOCKET	100NB BSP SOCKET				
14	100NB	SOCKET	100NB BSP SOCKET				
2	100NB	SOCKET	100NB BSP SOCKET	B		14/3/02	
1	100NB	SOCKET	100NB BSP SOCKET	A		-	

DRAWN: V.B.B.		App. Weight: 1,508 kg		Construction Type		Compartment Configuration		DRAWING NUMBER:		REVISION:			
DATE: 25-07-01		App. Capacity: 51,200 L		SINGLE WALL		TYPE 50		SINGLE		FS 050000-000		B	

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage Tanks as illustrated. Sizes & fittings shall be as noted. The Tanks shall be "Century-Cast" Tanks as manufactured by Fibretank Systems Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON., NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812