



▶▶ HOLD DOWN STRAP LOCATION * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION	Type	Notes	Revision Details	By	Date
FLAT No.	SIZE						
25	100NB	SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.	A	Original Issue	-
14	100NB	SOCKET	100NB BSP SOCKET	- Dedmen to suit this tank are part no.			
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- UNQ, all sockets are BSP and are c/w striker plates under.			
DRAWN: V.B.B.		App. Weight: 1,850kg		Construction		Type	
DATE: 11-12-01		App. Capacity: 51,200 L		SINGLE WALL		TYPE 50	
				SINGLE		SINGLE	
				DRAWING NUMBER: FP 050000-000		REVISION: A	

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON, NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812