



TANK 1 VOLUME = 35,114L

TANK 2 VOLUME = 19,662L

◆◆ HOLD DOWN STRAP LOCATION

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM	DESCRIPTION	No	Original Issue	By	Date
25-26	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				
22	100NB	SOCKET	100NB BSP SOCKET				
20	100NB	SOCKET	100NB BSP SOCKET				
13	100NB	SOCKET	100NB BSP SOCKET				
6	100NB	SOCKET	100NB BSP SOCKET				
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	A	Original Issue		

DRAWN: V.B.B.	App. Weight: 1,956 kg	Construction	Type	Compartment Configuration	DRAWING NUMBER:	REVISION:
DATE: 01-08-01	App. Capacity: 54,776 L	SINGLE WALL TYPE 55		DOUBLE 30/25	FT 055000-000	A

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON., NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812