



TANK 1 VOLUME = 29,744 L

TANK 2 VOLUME = 25,032 L

▶▶ HOLD DOWN STRAP LOCATION

\* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION	Notes	Revision Details	By	Date
FLAT No.	SIZE					
27	100NB	SOCKET	100NB BSP SOCKET			
26	100NB	SOCKET	100NB BSP SOCKET			
25	100NB	SOCKET	100NB BSP SOCKET			
22	100NB	SOCKET	100NB BSP SOCKET			
17	100NB	SOCKET	100NB BSP SOCKET			
13	100NB	SOCKET	100NB BSP SOCKET			
6	100NB	SOCKET	100NB BSP SOCKET			
3	100NB	SOCKET	100NB BSP SOCKET			
2	100NB	SOCKET	100NB BSP SOCKET			
1	100NB	SOCKET	100NB BSP SOCKET			

FIBRETANK SYSTEMS Pty Limited

DRAWN: V.B.B. App. Weight: 1,868 kg

DATE: 31-07-01 App. Capacity: 54,776 L

Construction Type SINGLE WALL TYPE 55

Compartment Configuration DOUBLE 30/25

DRAWING NUMBER: FG 055000-000

REVISION: A

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
PO BOX 102  
CARRINGTON, NSW 2294  
Ph:(02)4961-2745 Fax:(02)4962-2812