



▶▶ HOLD DOWN STRAP LOCATION \* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM		No	Revision	By	Date
27	100NB	SOCKET	100NB BSP SOCKET				
26	100NB	SOCKET	100NB BSP SOCKET				
25	100NB	SOCKET	100NB BSP SOCKET				
17	100NB	SOCKET	100NB BSP SOCKET	B	SUPA-RIB Removed	KJM	04.10.05
2	100NB	SOCKET	100NB BSP SOCKET	A	Original Issue	-	-

DRAWN: V.B.B.		App. Weight: 1,698 kg		Construction		Type		Compartment Configuration		DRAWING NUMBER:		REVISION:			
DATE: 30-07-01		App. Capacity: 54,776 L		SINGLE WALL		TYPE 55		SINGLE		FS 055000-000		B			
<p>The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes &amp; fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested &amp; installed as per current specifications and instructions.</p>				<p>All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.</p>				<p>THIS DRAWING &amp; THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL &amp; MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED</p>				<p>FIBRETANK SYSTEMS Pty Limited PO BOX 102 CARRINGTON, NSW 2294 Ph:(02)4961-2745 Fax:(02)4962-2812</p>			

FIBRETANK SYSTEMS Pty Limited

SINGLE WALL

TYPE 55

SINGLE

FS 055000-000

REVISION: B