



◆◆ HOLD DOWN STRAP LOCATION * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
27	100NB	SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.	B	SUPA-RIB Removed	KJM 04.10.05
17	100NB	SOCKET	100NB BSP SOCKET	- Dedmen to suit this tank are part no.	A	Original Issue	-
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- UNO, all sockets are BSP and are c/w striker plates under.	No		
FLAT No.	SIZE	ITEM	DESCRIPTION				By
							Date

DRAWN: V.B.B.		App. Weight:	1,748 KG	Construction		Type	Compartment Configuration	DRAWING NUMBER:	REVISION:	
DATE: 25-10-01		App. Capacity:	54,776 L	SINGLE WALL		TYPE 55	SINGLE	FP 055000-000	B	
<p>The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.</p>				<p>All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.</p>				<p>THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED</p>		<p>FIBRETANK SYSTEMS Pty Limited PO BOX 102 CARRINGTON., NSW 2294 Ph:(02)4961-2745 Fax:(02)4962-2812</p>