



FIBRETANK SYSTEMS Pty Limited  
 \* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		NOTES		DRAWING NUMBER:		REVISION:	
DOMES	SIZE	ITEM	DESCRIPTION	Notes	No	Revision Details	By	Date	
DOMES	100NB	SOCKET	100NB BSP SOCKET						
12-13	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID						
10	100NB	SOCKET	100NB BSP SOCKET						
5	100NB	SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.					
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- Dedmen to suit this tank are part no.					
DOMES	100NB	SOCKET	100NB BSP SOCKET	- UNO, all sockets are BSP and are c/w striker plates under.	A	Original Issue			
FLAT NO.	SIZE	ITEM	DESCRIPTION	Notes	No	Revision Details	By	Date	
DRAWN: V.B.B.		App. Weight:	2,275 kg	Construction		Type	DOUBLE 30/30		REVISION: A
DATE: 01-08-01		App. Capacity:	62,186 L	Type		TYPE 60	DOUBLE 30/30		
<p>The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes &amp; fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested &amp; installed as per current specifications and instructions.</p> <p>All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.</p> <p>THIS DRAWING &amp; THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL &amp; MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED</p> <p>FIBRETANK SYSTEMS Pty Limited          PO BOX 102          CARRINGTON., NSW 2294          Ph:(02)4961-2745 Fax:(02)4962-2812</p>									