



TANK 1 VOLUME = 19,668 L APPROX

TANK 1 VOLUME = 26,214 L APPROX

TANK 1 VOLUME = 14,304 L APPROX

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM		No	Original Issue	By	Date
30	100NB	SOCKET	100NB BSP SOCKET				
28-29	100NB	SOCKET	100NB BSP SOCKET				
26-27	100NB	SOCKET	100NB BSP SOCKET				
22	100NB	SOCKET	100NB BSP SOCKET				
14-17	100NB	SOCKET	100NB BSP SOCKET				
12-13	100NB	SOCKET	100NB BSP SOCKET				
8	100NB	SOCKET	100NB BSP SOCKET				
6	100NB	SOCKET	100NB BSP SOCKET				
3	100NB	SOCKET	100NB BSP SOCKET				
1-2	100NB	SOCKET	100NB BSP SOCKET				

DRAWN: V.B.B. DATE: 17-10-02	App. Weight: 2,198 kg App. Capacity: 60,186 L	Construction Type SINGLE WALL TYPE 60	Compartment Configuration TRIPLE	DRAWING NUMBER: FH 060000-000	REVISION: A
---------------------------------	--	---	--	---	-----------------------

▶▶ HOLD DOWN STRAP LOCATION * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON, NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812