



◆◆ HOLD DOWN STRAP LOCATION * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		NOTES		DRAWING NUMBER:		REVISION:	
FLAT NO.	SIZE	ITEM	DESCRIPTION	Notes	No	Revision Details	By	Date	
DOME	100NB	SOCKET	100NB BSP SOCKET						
12-13	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID						
10	100NB	SOCKET	100NB BSP SOCKET						
5	100NB	SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.					
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- Dedmen to suit this tank are part no.					
DOME	100NB	SOCKET	100NB BSP SOCKET	- UNO, all sockets are BSP and are c/w striker plates under.	A	Original Issue			
DRAWN: V.B.B.	App. Weight:	2,275 kg	Construction	Type	Compartment Configuration	DRAWING NUMBER:	FT 060000-000	REVISION:	
DATE: 01-08-01	App. Capacity:	62,186 L	SINGLE WALL	TYPE 60	DOUBLE	30/30		A	

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON, NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812