



TANK 1 VOLUME = 39,275 L

TANK 2 VOLUME = 32,730 L

FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FIBRETANK SYSTEMS Pty Limited

FITTING SCHEDULE		DESCRIPTION		NOTES		REVISION:	
FITTING No.	SIZE	ITEM	DESCRIPTION	No	Revision Details	By	Date
15-16	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				
13	100NB	SOCKET	100NB BSP SOCKET				
12	100NB	SOCKET	100NB BSP SOCKET				
7	100NB	SOCKET	100NB BSP SOCKET		- Tie-Down Straps to suit this tank are part no.		
5	100NB	SOCKET	100NB BSP SOCKET		- Dedmen to suit this tank are part no.		
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	A	Original Issue		
FLAT No.				Notes		Revision Details	
DRAWN: V.B.B.				App. Weight: 2,547 kg		DRAWING NUMBER: FT 070000-000	
DATE: 01-08-01				App. Capacity: 72,005 L		REVISION: A	

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON., NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812