



TANK 1 VOLUME = 19,638 L

TANK 2 VOLUME = 32,729 L

TANK 3 VOLUME = 19,638 L

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

▶▶ HOLD DOWN STRAP LOCATION

FITTING SCHEDULE

FLAT No.	SIZE	ITEM	DESCRIPTION	Notes	Revision Details	By	Date
16-17	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				
14	100NB	SOCKET	VENT ONLY				
10-11	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				
8	100NB	SOCKET	100NB BSP SOCKET	- The-Down Straps to suit this tank are part no.	C	NOTE FOR TUNNEL ADDED	V.B.B. 4-7-01
7	100NB	SOCKET	100NB BSP SOCKET	- Deadmen to suit this tank are part no.	B	TEXT UPDATED	V.B.B. 8-6-01
4	100NB	SOCKET	VENT ONLY		A	Original Issue	-
1-2	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- UNO, all sockets are BSP and are c/w striker plates under.	No		

DRAWN: V.B.B. App. Weight: 2547KG

DATE: 1-06-01 App. Capacity: 72,005 L Construction Type: SINGLE WALL TYPE 70

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON, NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812