



TANK 1 VOLUME = 39,275 L APPROX

TANK 2 VOLUME = 42,549 L APPROX

▶▶ HOLD DOWN STRAP LOCATION * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		NOTES		REVISION:	
FLAT No.	SIZE	ITEM	DESCRIPTION	No	Revision Details	By	Date
18-19	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				
15	100NB	SOCKET	100NB BSP SOCKET				
13	100NB	SOCKET	100NB BSP SOCKET				
7	100NB	SOCKET	100NB BSP SOCKET				
5	100NB	SOCKET	100NB BSP SOCKET				
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	A	Original Issue		

DRAWN: V.B.B.		App. Weight: 2,827 kg		Construction Type		Compartment Configuration		DRAWING NUMBER:		REVISION:	
DATE: 01-08-01		App. Capacity: 81,824 L		SINGLE WALL TYPE 80		DOUBLE 40/40		FT 080000-000		A	

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON., NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812