



TANK 1 VOLUME = 62,186 L

TANK 2 VOLUME = 29,457 L

▶▶ HOLD DOWN STRAP LOCATION

\* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		NOTES		REVISION:	
FLAT No.	SIZE	ITEM	DESCRIPTION	No	Revision Details	By	Date
DOME	100NB	SOCKET	100NB BSP SOCKET				
21-22	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				
19	100NB	SOCKET	100NB BSP SOCKET				
13	100NB	SOCKET	100NB BSP SOCKET				
6	100NB	SOCKET	100NB BSP SOCKET				
21-22	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	A	Original Issue		
DRAWN: V.B.B.		App. Weight:	3,103 kg	Construction		Type	
DATE: 01-08-01		App. Capacity:	91,643 L	SINGLE WALL		TYPE 90	
				DOUBLE		60/30	
				DRAWING NUMBER:		FT 090000-000	
				REVISION:		A	

FIBRETANK SYSTEMS Pty Limited

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
 PO BOX 102  
 CARRINGTON, NSW 2294  
 Ph:(02)4961-2745 Fax:(02)4962-2812