



TANK 1 VOLUME = 26,720 L APPROX

TANK 2 VOLUME = 19,280 L APPROX

ITEM	DESCRIPTION	WEIGHT
F5	RUST RED FLOWCOAT	-
F4	GLASS OWENN'S CORNINS 360 RR	-
F3	CATALYST	-
F2	AROPOL 7241PS/PW	-
F1	TEXOPRINT MAT	-

FIBREGLASS

ITEM	DESCRIPTION	QTY	PART / SUB ASSM No.
S1	HOLD DOWN STRAPS	4	015002
	VACUUM MONITOR	1	006137, 017111, 017160
	LIFTING LUG COVER	2	015071
	DIPSTICK 26.720 L	1	SPECIAL
	DIPSTICK 19.280 L	1	SPECIAL
	ACCESSORIES	QTY	PART / SUB ASSM No.

- NOTE:
- VACUUM ON INTERSTITIAL SPACE IS FACTORY SET & GAUGE SET
 - INSTALLATION AS PER GLASTEEL II INSTALLATION INSTRUCTIONS & APPLICABLE CODES
 - VESSEL IDENTIFICATION No. & MANUFACTURE DATE ARE LAMINATED TO TOP OF VESSEL
 - VESSEL MANUFACTURED TO AS1692
 - PLASTIC LIFTING LUG COVERS SUPPLIED WITH VESSEL
 - HOLD DOWN STRAPS POSITION ARE TO BE MARKED ON VESSEL DURING MANUFACTURING
 - ALL SOCKETS TO BE CLEANED AND FITTED WITH PLASTIC DUST CAPS
 - 6mm STRIKER PLATES TO BE FITTED UNDER ALL OPENINGS
 - ALL WELDS AS PER AS1554.1-GP (ND.T. - VISUAL)
 - VOLUME = 46,000 L (APPROX)
 - WEIGHT OF TANK = 4,425kg (APPROX)

No.	REVISION DETAILS	BY	DATE
A	ORIGINAL ISSUE	0	0
B	SCHEDULE AMENDED	ND	7.6.05
C			
D			
E			
F			

CLIENT:	DATE:
FTS STD	11-07-01
DRAWN: V.B.B.	
CHECKED:	DATE:
APPROVED:	DATE:
ORDER No:	No OFF: ONE (1)
SCALE: 1:	CAD REF: JD-GST-DC-S

Dimension in millimetres to the applicable design code of manufacture, and/or client requirement.

JOB No:	SHEET: 1 of 1	REVISION: A

TITLE:	ESTIMATE NUMBER:	DRAWING NUMBER:	VESEL CLASS
GENERAL ARRANGEMENT T40 SPLIT (25/15) GLASTEEL II U/G STORAGE VESSEL (6mm SHELL)	N/A	JD 040000-000	N/A

ITEM	DESCRIPTION	PART / SUB ASSM No.
9	1 SHELL: 2750 ID x 6 PL x 1500 LONG	SUB 1260
8	6 STRIKER PLATE	SUB 1047
7	2 LIFTING LUG - 5 TONNE C/W DOUBLER PAD	SUB1076
6	3 END SLIP IN 2750 ID x 6 PLATE	SUB1015
5	2 SHELL 2750 ID x 6 PLATE x 3000 LONG	SUB1039
4	1 50NB MONITOR SOCKET C/W INTERNAL PIPE	SUB1060
3	2 100NB FILL SOCKET C/W PIPE	SUB1057
2	2 80NB DIP SOCKET C/W PIPE	SUB1052
1	6 100NB PHOENIX FLANGE	006395

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED

PO BOX 102
CARINGTON N.S.W. 2294
PHONE (02) 4961-2745
FAX (02) 4962-2812

PTV LIMITED

FIBRETANK SYSTEMS

REVISION: A

SHEET SIZE A3