


- NOTE:
- VACUUM ON INTERSTITIAL SPACE IS FACTORY SET & GAUGE SET
 - INSTALLATION AS PER GLASTEEL II INSTALLATION INSTRUCTIONS & APPLICABLE CODES
 - VESSEL IDENTIFICATION No. & MANUFACTURE DATE ARE LAMINATED TO TOP OF VESSEL
 - VESSEL MANUFACTURED TO AS1692
 - PLASTIC LIFTING LUG COVERS SUPPLIED WITH VESSEL
 - HOLD DOWN STRAPS POSITION ARE TO BE MARKED ON VESSEL DURING MANUFACTURING
 - ALL SOCKETS TO BE CLEANED AND FITTED WITH PLASTIC DUST CAPS
 - 6mm STRIKER PLATES TO BE FITTED UNDER ALL OPENINGS
 - ALL WELDS AS PER AS1554.1-GP (N.D.T. - VISUAL)
 - VOLUME = 16,480 L (APPROX)
 - WEIGHT OF TANK = 1,670 kg (APPROX)

No.	REVISION DETAILS	BY	DATE
F			
E			
D			
C			
B			
A	ORIGINAL ISSUE		

CLIENT:		FTS STD	
DRAWN:	V.B.B.	DATE:	11-07-01
CHECKED:		DATE:	
APPROVED:		DATE:	
ORDER No:		No OFF:	ONE (1)
SCALE:	1:25	CAD REF:	JW-GST-SC-P



ITEM	QTY	DESCRIPTION	PART / SUB ASSM No.
S1	2	HOLD DOWN STRAPS	015001
	1	VACUUM MONITOR GAUGE	006137, 017711, 017160
	2	LIFTING LUG COVERS	015071
	1	DIPSTICK T15	SUB1063
		ACCESSORIES	QTY PART / SUB ASSM No.

ITEM	QTY	DESCRIPTION	PART / SUB ASSM No.
10	1	STRIKER PLATE	SUB1047
9	1	PHOENIX FLANGE	006395
8	1	FRP COLLAR	SUB1028
7	2	LIFTING LUG - 2 TONNE	SUB1075
6	2	END Ø2190 I.D x 6 PLATE	SUB1004
5	2	SHELL Ø2190 I.D x 6 PLATE x 2100 LONG	SUB1037
4	2	50NB MONITOR SOCKET C/W INTERNAL PIPE	SUB1081
3	1	100NB FILL SOCKET C/W PIPE	SUB1056
2	1	50NB DIP SOCKET C/W PIPE	SUB1050
1	1	600NB MANWAY C/W 5 x 100NB SOCKETS	SUB1095

FIBRETEK SYSTEMS PTY LIMITED		PO BOX 102 CARRINGTON N.S.W. 2294 PHONE (02) 4961-2745 FAX: (02) 4962-2812	
THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETEK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETEK SYSTEMS Pty LIMITED			
TITLE:		GENERAL ARRANGEMENT T15	
GLASTEEL II U/G STORAGE VESSEL (6mm SHELL)		VESSEL CLASS	
ESTIMATE NUMBER:		DRAWING NUMBER:	
N/A		JW 015000-000	
JOB No:		SHEET: 1 of 1	
		REVISION: A	
		SHEET SIZE	
		A3	