



| | | |
|------|-----------------------------|--------|
| F5 | RUST RED FLOWCOAT | - |
| F4 | GLASS OWENNS CORNINS 360 RR | - |
| F3 | CATALYST | - |
| F2 | AROPOL 7241PS/PW | - |
| F1 | TEXOPRINT MAT | - |
| ITEM | DESCRIPTION | WEIGHT |

FIBREGLASS

- NOTE:
- VACUUM ON INTERSTITIAL SPACE IS FACTORY SET & GAUGE SET
 - INSTALLATION AS PER GLASTEEL II INSTALLATION INSTRUCTIONS & APPLICABLE CODES
 - VESSEL IDENTIFICATION No. & MANUFACTURE DATE ARE LANMATED TO TOP OF VESSEL
 - VESSEL MANUFACTURED TO AS1692
 - PLASTIC LIFTING LUG COVERS SUPPLIED WITH VESSEL
 - HOLD DOWN STRAPS POSITION ARE TO BE MARKED ON VESSEL DURING MANUFACTURING
 - ALL SOCKETS TO BE CLEANED AND FITTED WITH PLASTIC DUST CAPS
 - 6mm STRIKER PLATES TO BE FITTED UNDER ALL OPENINGS
 - ALL CIRC JOINTS TO BE JOGGLED
 - VOLUME = 2,520 L (APPROX)
 - WEIGHT OF TANK = 520 kg (APPROX)

| | | | |
|----|----------------------|-----|-----------------------|
| S1 | HOLD DOWN STRAPS | 2 | T.B.A. |
| | VACUUM MONITOR GAUGE | 1 | 006137 017111, 017160 |
| | LIFTING LUG COVERS | 2 | 015071 |
| | DIPSTICK T2 | 1 | SUB1018 |
| | ACCESSORIES | QTY | PART / SUB ASSM No. |

| | | | |
|------|-----|---|---------------------|
| 9 | 2 | STRIKER PLATE | SUB1047 |
| 8 | 1 | FRP COLLAR | SUB1028 |
| 7 | 2 | LIFTING LUG - 2 TONNE | SUB1075 |
| 6 | 2 | END 1143 I.D x 6 PLATE | SUB1000 |
| 5 | 1 | SHELL 1143 I.D x 6 PLATE x 2400 LONG | SUB1034 |
| 4 | 2 | 100NB SOCKET BSP BLANK | 006229 |
| 3 | 1 | 50NB MONITOR SOCKET C/W INTERNAL PIPE | SUB1079 |
| 2 | 1 | 50NB DIP SOCKET C/W PIPE & CALIBRATED DIP STICK | SUB1048 |
| 1 | 1 | 600NB MANWAY C/W 5 x 100NB SOCKETS | SUB1095 |
| ITEM | QTY | DESCRIPTION | PART / SUB ASSM No. |

FIBRETEK SYSTEMS
PTY LIMITED

PO BOX 102
CARRINGTON N.S.W. 2294
PHONE: (02) 4961-2745
FAX: (02) 4962-2812

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETEK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETEK SYSTEMS Pty LIMITED

TITLE: GENERAL ARRANGEMENT T2
GLASTEEL II U/G STORAGE VESSEL (6mm SHELL)

ESTIMATE NUMBER: N/A

DRAWING NUMBER: JW 002000-000

JOB No.: SHEET: 1 of 1 REVISION: A

VESSEL CLASS: N/A

SHEET SIZE: A3

| | | | | |
|-----|------------------|----|------|----------------------------------|
| No. | REVISION DETAILS | BY | DATE | CLIENT: |
| F | | | | FTS STD |
| E | | | | DRAWN: V.B.B. |
| D | | | | CHECKED: DATE: 11-07-01 |
| C | | | | APPROVED: DATE: |
| B | | | | ORDER No: No OFF: ONE (1) |
| A | ORIGINAL ISSUE | | | SCALE: 1:20 CAD REF: JW-GST-SC-0 |

Dimension in millimetres to be to the applicable design code of manufacture, and/or client requirement.