



| ITEM | DESCRIPTION | WEIGHT |
|------|-----------------------------|--------|
| F5 | RUST RED FLOWCOAT | - |
| F4 | GLASS OWENNS CORNINS 360 RR | - |
| F3 | CATALYST | - |
| F2 | AROPOL 7241 PS/PW | - |
| F1 | STAND OFF MATERIAL | - |

FIBREGLASS

NOTE:

- 1: VACUUM ON INTERSTITIAL SPACE IS FACTORY SET & GAUGE SET
- 2: INSTALLATION AS PER GLASTEEL II INSTALLATION INSTRUCTIONS & APPLICABLE CODES
- 3: VESSEL IDENTIFICATION No. & MANUFACTURE DATE ARE LAMINATED TO TOP OF VESSEL
- 4: VESSEL MANUFACTURED TO AS1692
- 5: PLASTIC LIFTING LUG COVERS SUPPLIED WITH VESSEL
- 6: HOLD DOWN STRAPS POSITION ARE TO BE MARKED ON VESSEL DURING MANUFACTURING
- 7: ALL SOCKETS TO BE CLEANED AND FITTED WITH PLASTIC DUST CAPS
- 8: 6mm STRIKER PLATES TO BE FITTED UNDER ALL OPENINGS
- 9: ALL WELDS AS PER AS1554.1-GP (N.D.T. - VISUAL)
- 10: VOLUME = 21,000 L (APPROX)
- 11: WEIGHT OF TANK = 2,065 kg (APPROX)

| No. | REVISION DETAILS | BY | DATE |
|-----|--|--------|----------|
| F | | | |
| E | | | |
| D | | | |
| C | | | |
| B | ITEM 1 WAS 100NB PHOENIX FLANGE TEXT UPDATED | V.B.B. | 20-12-02 |
| A | ORIGINAL ISSUE | | |

| | | |
|---|---------------|----------------------|
| CLIENT: FTS STD | | DATE: 11-07-01 |
| DRAWN: V.B.B. | | DATE: 11-07-01 |
| CHECKED: | | DATE: |
| APPROVED: | | DATE: |
| ORDER No: | | No OFF: ONE (1) |
| SCALE: 1:30 | | CAD REF: JW-GST-SC-P |
| Dimension in millimetres to the applicable design code of manufacture, and/or client requirement. | | |
| JOB No: | SHEET: 1 of 1 | REVISION: B |

| ITEM | QTY | DESCRIPTION | PART / SUB ASSM No. |
|------|-----|----------------------|------------------------|
| S1 | 3 | HOLD DOWN STRAPS | 015001 |
| | 1 | VACUUM MONITOR GAUGE | 006137, 017111, 017160 |
| | 2 | LIFTING LUG COVERS | 015071 |
| | 1 | DIPSTICK 120 | SUB1064 |
| | | ACCESSORIES | QTY |
| | | | PART / SUB ASSM No. |

| ITEM | QTY | DESCRIPTION | PART / SUB ASSM No. |
|------|-----|--------------------------------------|---------------------|
| 11 | 1 | STRIKER PLATE | SUB1047 |
| 10 | 1 | 600NB MANWAY C/W 5 x 100NB SOCKETS | SUB1095 |
| 9 | 1 | FRP COLLAR | SUB1028 |
| 8 | 2 | LIFTING LUG - 2 TONNE | SUB1075 |
| 7 | 2 | END Ø2190 ID x 6 PLATE | SUB1004 |
| 6 | 1 | SHELL Ø2190 ID x 6 PLATE x 3000 LONG | SUB1036 |
| 5 | 1 | SHELL Ø2190 ID x 6 PLATE x 2400 LONG | SUB1038 |
| 4 | 1 | 50NB MONITOR PIPE | SUB1081 |
| 3 | 1 | 100NB FILL SOCKET C/W PIPE | SUB1056 |
| 2 | 1 | 50NB DIP SOCKET C/W PIPE | SUB1050 |
| 1 | 1 | 100NB BLACK STEEL SOCKET | 006395 |

FIBRETEK SYSTEMS
 PTY LIMITED
 PO BOX 102
 CARRINGTON N.S.W. 2294
 PHONE: (02) 4961-2745
 FAX: (02) 4962-2812

TITLE: GENERAL ARRANGEMENT T20
GLASTEEL II PRESSURE SYSTEM (6mm SHELL)
ESTIMATE NUMBER: N/A
DRAWING NUMBER: JW 020000-000
SHEET: 1 of 1
REVISION: B
VESSEL CLASS: N/A
SHEET SIZE: A3