



PLAN VIEW ON MANWAY

- NOTE:
- VACUUM ON INTERSTITIAL SPACE IS FACTORY SET & GAUGE SET
 - INSTALLATION AS PER GLASTEEL II INSTALLATION INSTRUCTIONS & APPLICABLE CODES
 - VESSEL IDENTIFICATION No. & MANUFACTURE DATE ARE LAMINATED TO TOP OF VESSEL
 - VESSEL MANUFACTURED TO ASK692
 - PLASTIC LIFTING LUG COVERS SUPPLIED WITH VESSEL
 - HOLD DOWN STRAPS POSITION ARE TO BE MARKED ON VESSEL DURING MANUFACTURING
 - ALL SOCKETS TO BE CLEANED AND FITTED WITH PLASTIC DUST CAPS
 - 6mm STRIKER PLATES TO BE FITTED UNDER ALL OPENINGS
 - ALL WELDS AS PER AS1554.1-GP (N.D.T. - VISUAL)
 - VOLUME = 4,2,4,70 L (APPROX)
 - WEIGHT OF TANK = 3,850 kg (APPROX)

| No. | REVISION DETAILS | BY | DATE |
|-----|------------------|----|------|
| A | ORIGINAL ISSUE | | |
| B | | | |
| C | | | |
| D | | | |
| E | | | |
| F | | | |

| | | | |
|---|--------|-----------------|---------------|
| CLIENT: | | FTS STD | |
| DRAWN: | V.B.B. | DATE: | 11-07-01 |
| CHECKED: | | DATE: | |
| APPROVED: | | DATE: | |
| ORDER No.: | | No OFF: | ONE (1) |
| SCALE: | N.T.S. | CAD REF: | JW-GST-SC-P |
| Dimension in millimetres to be to the applicable design code of manufacture, and/or client requirement. | | | |
| JOB No.: | | DRAWING NUMBER: | JW 042000-000 |
| | | SHEET: 1 of 1 | REVISION: A |

| ITEM | DESCRIPTION | WEIGHT |
|------|-----------------------------|--------|
| F5 | RUST RED FLOWCOAT | - |
| F4 | GLASS OWENNS CORNINS 360 RR | - |
| F3 | CATALYST | - |
| F2 | AROPOL 7241 PS/PW | - |
| F1 | STAND OFF MATERIAL | - |

| ITEM | DESCRIPTION | QTY | PART / SUB ASSM No. |
|------|-------------------|-----|------------------------|
| S1 | HOLD DOWN STRAPS | 4 | 015001 |
| | VACUUM MONITOR | 1 | 006137, 017711, 017160 |
| | LIFTING LUG COVER | 2 | 015071 |
| | DIPSTICK 142 | 1 | SUB1069 |
| | ACCESSORIES | | |

| ITEM | DESCRIPTION | QTY | PART / SUB ASSM No. |
|------|---|-----|---------------------|
| 11 | 1 STRIKER PLATE | | SUB1047 |
| 10 | 2 LIFTING LUG - 5 TONNE C/W DOUBLER PAD | | SUB1076 |
| 9 | 2 END Ø2190 ID x 5 PLATE | | SUB1004 |
| 8 | 1 SHELL Ø2190 ID x 5 PLATE x 2100 LONG | | SUB1037 |
| 7 | 3 SHELL Ø2190 ID x 5 PLATE x 3000 LONG | | SUB1036 |
| 6 | 1 FRP COLLAR | | SUB1028 |
| 5 | 1 600NB MANWAY C/W 5 x 100NB SOCKETS | | SUB1095 |
| 4 | 1 50NB (NPT) MONITOR SOCKET C/W INTERNAL PIPE | | SUB1081 |
| 3 | 1 100NB FILL SOCKET C/W PIPE | | SUB1056 |
| 2 | 1 80NB DIP SOCKET C/W PIPE | | SUB1051 |
| 1 | 1 100NB PHOENIX FLANGE | | 006395 |

FIBRETEK SYSTEMS
PTY LIMITED

PO BOX 102
CARRINGTON N.S.W. 2294
PHONE (02) 4961-2745
FAX (02) 4962-2812

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETEK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETEK SYSTEMS Pty LIMITED

TITLE: GENERAL ARRANGEMENT T42
GLASTEEL II U/G STORAGE VESSEL (5mm PLATE)

ESTIMATE NUMBER: N/A

DRAWING NUMBER: JW 042000-000

VESEL CLASS: N/A

SHEET SIZE: A3