



PLAN VIEW ON MANWAY

ITEM	DESCRIPTION	WEIGHT
F5	RUST RED FLOWCOAT	-
F4	GLASS OWENN'S CORNINS 360 RR	-
F3	CATALYST	-
F2	AROPOL 7241PS/PW	-
F1	TEXOPRINT MAT	-

FIBREGLASS

- NOTE:
- VACUUM ON INTERSTITIAL SPACE IS FACTORY SET & GAUGE SET
  - INSTALLATION AS PER GLASTEEL II INSTALLATION INSTRUCTIONS & APPLICABLE CODES
  - VESSEL IDENTIFICATION No. & MANUFACTURE DATE ARE LAMINATED TO TOP OF VESSEL
  - VESSEL MANUFACTURED TO AS1692 AND AIR TESTED TO 35kPa
  - PLASTIC LIFTING LUG COVERS SUPPLIED WITH VESSEL
  - HOLD DOWN STRAPS POSITION ARE TO BE MARKED ON VESSEL DURING MANUFACTURING
  - ALL SOCKETS TO BE CLEANED AND FITTED WITH PLASTIC DUST CAPS
  - 6mm STRIKER PLATES TO BE FITTED UNDER ALL OPENINGS
  - ALL WELDS AS PER AS1554.1-GP (IND. T. VISUAL)
  - VOLUME = 5,100 L (APPROX)
  - WEIGHT OF TANK = 765 kg (APPROX)

ACCESSORIES	QTY	PART / SUB ASSM No
FRP HOLD DOWN STRAPS	2	015006
VACUUM MONITOR GAUGE	1	006337, 017111, 017160
LIFTING LUG COVERS	2	015071
DIPSTICK T5	1	SUB1019

ITEM	QTY	DESCRIPTION	PART / SUB ASSM No.
8	2	LIFTING LUG - 2 TONNE	SUB1075
7	2	END 1445 ID x 6 PLATE	SUB1001
6	1	SHELL 1445 ID x 6 PLATE x 3000 LONG	SUB1035
5	1	FRP COLLAR	SUB1028
4	1	50NB MONITOR SOCKET C/W INTERNAL PIPE	SUB1080
3	1	50NB DIP SOCKET C/W INTERNAL PIPE	SUB1049
2	1	100NB FILL SOCKET C/W PIPE	SUB1055
1	1	600NB MANWAY C/W 5 x 100NB SOCKETS	-

No.	REVISION DETAILS	BY	DATE
F			
E			
D			
C			
B	NOZZLE & LIFTING LUG POSITION UPDATED	V.B.B.	19-03-03
A	ORIGINAL ISSUE		

CLIENT:	FTS STD
DRAWN: V.B.B.	DATE: 11-07-01
CHECKED:	DATE:
APPROVED:	DATE:
ORDER No:	No OFF: ONE (1)
SCALE: 1:25	CAD REF: JW-GST-SC-1

TITLE:	GENERAL ARRANGEMENT T5	VESSEL CLASS	N/A
ESTIMATE NUMBER:	N/A	DRAWING NUMBER:	JW 005000-000
JOB No:		SHEET: 1 of 1	REVISION: B
			SHEET SIZE
			A3

Dimension in millimetres to the applicable design code of manufacture, and/or client requirement.

PO BOX 102  
 CARRINGTON N.S.W. 2294  
 PHONE (02) 4961-2745  
 FAX (02) 4962-2812

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED