



- NOTE:
- VACUUM ON INTERSTITIAL SPACE IS FACTORY SET & GAUGE SET
  - INSTALLATION AS PER GLASTEEL II INSTALLATION INSTRUCTIONS & APPLICABLE CODES
  - VESSEL IDENTIFICATION No. & MANUFACTURE DATE ARE LAMINATED TO TOP OF VESSEL
  - VESSEL MANUFACTURED TO AS1692
  - PLASTIC LIFTING LUG COVERS SUPPLIED WITH VESSEL
  - HOLD DOWN STRAPS POSITION ARE TO BE MARKED ON VESSEL DURING MANUFACTURING
  - ALL SOCKETS TO BE CLEANED AND FITTED WITH PLASTIC DUST CAPS
  - 6mm STRIKER PLATES TO BE FITTED UNDER ALL OPENINGS
  - ALL WELDS AS PER AS1554.1-GP (N.D.T. - VISUAL)
  - VOLUME = 6730 L (APPROX)
  - WEIGHT OF TANK = 965 kg (APPROX)

ITEM	QTY	DESCRIPTION	PART / SUB ASSM No.
S1	2	HOLDING DOWN STRAPS	015001
	1	VACUUM MONITOR GAUGE	006137, 017711, 017160
	2	LIFTING LUG COVERS	015071
	1	DIPSTICK SPECIAL	SUB1020
		ACCESSORIES	PART / SUB ASSM No.

9	2	SHELL 1445 ID x 5 PLATE x 1000 LONG	-
8	2	LIFTING LUG - 2 TONNE	SUB1075
7	2	END 1445 ID x 6 PLATE	SUB1001
6	1	SHELL 1445 ID x 6 PLATE x 3000 LONG	SUB1035
5	1	FRP COLLAR	SUB1028
4	1	50NB MONITOR SOCKET (BSP) C/W INTERNAL PIPE	SUB1080
3	1	50NB DIP SOCKET C/W INTERNAL PIPE	SUB1049
2	1	100NB FILL SOCKET C/W PIPE	SUB1055
1	1	600NB MANWAY C/W 5 x 100NB SOCKETS	-

No.	REVISION DETAILS	BY	DATE	CLIENT:
F				FTS STD
E				DRAWN: V.B.B. DATE: 10-2-03
D				CHECKED: DATE:
C				APPROVED: DATE:
B				ORDER No: No OFF: ONE (1)
A	ORIGINAL ISSUE	0	0	SCALE: 1:25 CAD REF: JW-GST-SC-P

  

All tolerancing to be to the applicable design code of manufacture, and/or client requirement.	
Dimension in millimetres	
JOB No:	ESTIMATE NUMBER: N/A
DRAWING NUMBER: JW 006700-000	
SHEET: 1 of 1 REVISION: A	

  

TITLE: GENERAL ARRANGEMENT 6700 LITRE GLASTEEL II U/G STORAGE VESSEL (6mm SHELL)		VESSEL CLASS
FIBRETANK SYSTEMS PTY LIMITED PO BOX 102 CARARRINGTON N.S.W. 2294 PHONE (02) 4961-2745 FAX (02) 4962-2812		N/A
THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED		
SHEET: 1 of 1 REVISION: A		SHEET SIZE A3