



F5	RUST RED FLOWCOAT	-
F4	GLASS OWENN'S CORNINS 360 RR	-
F3	CATALYST	-
F2	AROPOL 7241PS/PW	-
F1	TEXOPRINT MAT	-
ITEM	DESCRIPTION	WEIGHT
FIBREGLASS		

S1	HOLD DOWN STRAPS	7	015003
	VACUUM MONITOR GAUGE	1	006137, 017711, 017760
	LIFTING LUG COVERS	2	015071
	DIPSTICK T110	1	SUB1073
	ACCESSORIES	QTY	PART / SUB ASSM No.

- 1: VACUUM ON INTERSTITIAL SPACE IS FACTORY SET & GAUGE SET
- 2: INSTALLATION AS PER GLASTEEL II INSTALLATION INSTRUCTIONS & APPLICABLE CODES
- 3: VESSEL IDENTIFICATION No. & MANUFACTURE DATE ARE LAMINATED TO TOP OF VESSEL
- 4: VESSEL MANUFACTURED TO AS1692
- 5: PLASTIC LIFTING LUG COVERS SUPPLIED WITH VESSEL
- 6: HOLD DOWN STRAPS POSITION ARE TO BE MARKED ON VESSEL DURING MANUFACTURING
- 7: ALL SOCKETS TO BE CLEANED AND FITTED WITH PLASTIC DUST CAPS
- 8: 6mm STRIKER PLATES TO BE FITTED UNDER ALL OPENINGS
- 9: ALL CIRC JOINTS TO BE JOGGLED
- 10: VOLUME = 116,000 L (APPROX)
- 11: WEIGHT OF TANK = 10,335 kg (APPROX)

No.	REVISION DETAILS	BY	DATE
F			
E			
D			
C			
B			
A	ORIGINAL ISSUE		

12	5	STRIKER PLATE	SUB1047
11	1	50NB MONITOR SOCKET C/W INTERNAL PIPE	SUB1082
10	2	LIFTING LUG - 7.5 TONNE C/W DOUBLER PAD	SUB1077
9	2	END D & F SLIP IN 3462 ID x 8 PLATE	SUB1017
8	3	SHELL 3462 ID x 8 PLATE x 3000 LONG	SUB1041
7	1	100NB PHOENIX FLANGE	006395
6	1	100NB PHOENIX FLANGE	006395
5	1	100NB FILL SOCKET C/W PIPE	SUB1058
4	1	100NB DIP SOCKET C/W PIPE	SUB1053
3	1	100NB PHOENIX FLANGE	006395
2	1	100NB PHOENIX FLANGE	006395
1	1	100NB PHOENIX FLANGE	006395
ITEM	QTY	DESCRIPTION	PART / SUB ASSM No.
FIBRETEK SYSTEMS			
PTY LIMITED			
PO BOX 102 CARINGTON N.S.W. 2294 PHONE (02) 4961-2745 FAX (02) 4962-2812			
THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETEK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETEK SYSTEMS Pty LIMITED			
TITLE: GENERAL ARRANGEMENT T110			
GLASTEEL II U/G STORAGE VESSEL (8mm SHELL)			
ESTIMATE NUMBER: N/A		DRAWING NUMBER: JS 110000-000	
JOB No:		SHEET: 1 of 1	
		REVISION: A	
		VESSEL CLASS N/A	
		SHEET SIZE A3	

CLIENT: FTS STD
 DRAWN: V.B.B. DATE: 10-07-01
 CHECKED: DATE:
 APPROVED: DATE:
 ORDER No: No OFF: ONE (1)
 SCALE: N.T.S. CAD REF: JS-GST-SC-S

Dimension in millimetres
 to be to the applicable design code of manufacture,
 and/or client requirement.