


NOTE:
 1: VACUUM ON INTERSTITIAL SPACE IS FACTORY SET & GAUGE SET
 2: INSTALLATION AS PER GLASTEEL II INSTALLATION INSTRUCTIONS & APPLICABLE CODES
 3: VESSEL IDENTIFICATION No. & MANUFACTURE DATE ARE LAMINATED TO TOP OF VESSEL
 4: VESSEL MANUFACTURED TO AS1692
 5: PLASTIC LIFTING LUG COVERS SUPPLIED WITH VESSEL
 6: HOLD DOWN STRAPS POSITION ARE TO BE MARKED ON VESSEL DURING MANUFACTURING
 7: ALL SOCKETS TO BE CLEANED AND FITTED WITH PLASTIC DUST CAPS
 8: 6mm STRIKER PLATES TO BE FITTED UNDER ALL OPENINGS
 9: ALL CIRC JOINTS TO BE JOGGLED
 10: VOLUME = 16,480 L (APPROX)
 11: WEIGHT OF TANK = 1,670 kg (APPROX)



| | | |
|------------|------------------------------|--------|
| F5 | RUST RED FLOWCOAT | - |
| F4 | GLASS OWENNS CORNINGS 360 RR | - |
| F3 | CATALYST | - |
| F2 | AROPOL 7241 PS/PW | - |
| F1 | TEXOPRINT MAT | - |
| ITEM | DESCRIPTION | WEIGHT |
| FIBREGLASS | | |

| | | | |
|----|----------------------|-----|------------------------|
| S1 | HOLD DOWN STRAPS | 2 | 015001 |
| | VACUUM MONITOR GAUGE | 1 | 006137, 017111, 017160 |
| | LIFTING LUG COVERS | 2 | 015071 |
| | DIPSTICK T15 | 1 | SUB1063 |
| | ACCESSORIES | QTY | PART / SUB ASSM No. |

| | | | |
|------|-----|--|---------------------|
| 11 | 4 | STRIKER PLATES | SUB1047 |
| 10 | 1 | 50NB BSP MONITOR SOCKET C/W INTERNAL PIPE | SUB1081 |
| 9 | 2 | LIFTING LUG - 2 TONNE | SUB1075 |
| 8 | 2 | END D & F ϕ 2190 ID x 6 PLATE | SUB1004 |
| 7 | 2 | SHELL ϕ 2190 ID x 6 PLATE x 2100 LONG | SUB1037 |
| 6 | 1 | 100NB BLACK STEEL SOCKET | - |
| 5 | 1 | 100NB FILL SOCKET C/W PIPE | SUB1056 |
| 4 | 1 | 50NB DIP SOCKET C/W PIPE | SUB1050 |
| 3 | 1 | 100NB BLACK STEEL SOCKET | - |
| 2 | 1 | 100NB BLACK STEEL SOCKET | - |
| 1 | 1 | 100NB BLACK STEEL SOCKET | - |
| ITEM | QTY | DESCRIPTION | PART / SUB ASSM No. |

| | | | | |
|-----|------------------------------------|--------|---------|---------------|
| No. | REVISION DETAILS | BY | DATE | CLIENT: |
| F | | | | FTS STD |
| E | | | | DRAWN: V.B.B. |
| D | | | | CHECKED: |
| C | | | | APPROVED: |
| B | 100NB SOCKETS WERE PHOENIX FLANGES | V.B.B. | 5-07-02 | ORDER No: |
| A | ORIGINAL ISSUE | 0 | 0 | SCALE: 1: |

| | | | |
|--|--|----------------------------------|--|
| FIBRETANK SYSTEMS | | JOB No: | |
| PTY LIMITED | | SHEET: 1 of 1 | |
| PO BOX 102 CARINGTON N.S.W. 2294 PHONE (02) 4961-2745 FAX: (02) 4962-2812 | | REVISION: B | |
| THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED | | DRAWING NUMBER: JS 015000-000 | |
| TITLE: GENERAL ARRANGEMENT T15 GLASTEEL II U/G STORAGE VESSEL (6mm SHELL) | | ESTIMATE NUMBER: N/A | |
| VESSEL CLASS N/A | | SHEET SIZE A3 | |