



F5	RUST RED FLOWCOAT	-
F4	GLASS OWENN'S CORNINS 360 RR	-
F3	CATALYST	-
F2	AROPOL 7241PS/PW	-
F1	TEXOPRINT MAT	-
ITEM	DESCRIPTION	WEIGHT

FIBREGLASS

- NOTE:
- VACUUM ON INTERSTITIAL SPACE IS FACTORY SET & GAUGE SET
 - INSTALLATION AS PER GLASTEEL II INSTALLATION INSTRUCTIONS & APPLICABLE CODES
 - VESSEL IDENTIFICATION NO. & MANUFACTURE DATE ARE LAMINATED TO TOP OF VESSEL
 - VESSEL MANUFACTURED TO AS1692
 - PLASTIC LIFTING LUG COVERS SUPPLIED WITH VESSEL
 - HOLD DOWN STRAPS POSITION ARE TO BE MARKED ON VESSEL DURING MANUFACTURING
 - ALL SOCKETS TO BE CLEANED AND FITTED WITH PLASTIC DUST CAPS
 - 6mm STRIKER PLATES TO BE FITTED UNDER ALL OPENINGS
 - ALL CIRC JOINTS TO BE JOGGLED
 - VOLUME = 2,520 L (APPROX)
 - WEIGHT OF TANK = 520 kg (APPROX)

- HOLD DOWN STRAPS (STEEL) 2
- VACUUM MONITOR GAUGE 1
- LIFTING LUG COVERS 2
- DIPSTICK 12 1
- ACCESSORIES 1

ITEM	QTY	DESCRIPTION	PART / SUB ASSM No.
9	3	STRIKER PLATE	SUB104.7
8	1	50NB (NPT) MONITOR SOCKET C/W INTERNAL PIPE	SUB1079
7	2	LIFTING LUG - 2 TONNE	SUB1075
6	2	END D & F ϕ 114.3 ID x 6 PLATE	SUB1000
5	1	SHELL 114.3 ID x 6 PLATE x 2400 LONG	SUB1034
4	1	80NB SOCKET BSP BLACK	00614.8
3	1	80NB SOCKET BSP BLACK	00614.8
2	1	50NB DIP SOCKET C/W PIPE	SUB104.8
1	1	100NB FILL SOCKET C/W PIPE	SUB1085

FIBRETEK SYSTEMS		PO BOX 102	
PTY LIMITED		CARARRINGTON N.S.W. 2294	
		PHONE (02) 4961-2745	
		FAX: (02) 4962-2812	

TITLE:		GENERAL ARRANGEMENT T2	
GLASTEEL II U/G STORAGE VESSEL (6mm SHELL)			
ESTIMATE NUMBER:	N/A	DRAWING NUMBER:	JS 002000-000
JOB No.:		SHEET: 1 of 1	REVISION: A

No.	REVISION DETAILS	BY	DATE	CLIENT:
F				FTS STD
E				DRAWN: V.B.B.
D				CHECKED:
C				APPROVED:
B				ORDER No.:
A	ORIGINAL ISSUE			SCALE: 1:20

DATE:	10-07-01
DATE:	
DATE:	
DATE:	
No OFF:	ONE (1)
CAD REF:	JS-GST-SC-S

All tolerancing to be to the applicable design code of manufacture, and/or client requirement.

VESSEL CLASS	N/A
SHEET SIZE	A3