



F5	RUST RED FLOWCOAT	-
F4	GLASS OWENN'S CORNINS 360 RR	-
F3	CATALYST	-
F2	AROPOL 7241PS/PW	-
F1	TEXOPRINT MAT	-
ITEM	DESCRIPTION	WEIGHT

**FIBREGLOSS**

S1	HOLD DOWN STRAPPS	4	015001
	VACUUM MONITOR	1	006137, 017111, 017071
	LIFTING LUG COVER	2	015071
	DIPSTICK T42	1	SUB1069
	ACCESSORIES	QTY	PART / SUB ASSM No.

- NOTE:
- VACUUM ON INTERSTITIAL SPACE IS FACTORY SET & GAUGE SET
  - INSTALLATION AS PER GLASTEEL II INSTALLATION INSTRUCTIONS & APPLICABLE CODES
  - VESSEL IDENTIFICATION No. & MANUFACTURE DATE ARE LAMINATED TO TOP OF VESSEL
  - VESSEL MANUFACTURED TO AS1692
  - PLASTIC LIFTING LUG COVERS SUPPLIED WITH VESSEL
  - HOLD DOWN STRAPS POSITION ARE TO BE MARKED ON VESSEL DURING MANUFACTURING
  - ALL SOCKETS TO BE CLEANED AND FITTED WITH PLASTIC DUST CAPS
  - 6mm STRIKER PLATES TO BE FITTED UNDER ALL OPENINGS
  - ALL CRC JOINTS TO BE JOGGLED
  - VOLUME = 42,470 L (APPROX)
  - WEIGHT OF TANK = 3,850 kg (APPROX)

No.	REVISION DETAILS	BY	DATE
F			
E			
D			
C			
B	100NB BLACK STEEL SOCKET WERE PHOENIX FLANGES	V.B.B.	27-08-03
A	ORIGINAL ISSUE	0	0

CLIENT:		FTS STD	
DRAWN:	V.B.B.	DATE:	10-07-01
CHECKED:		DATE:	
APPROVED:		DATE:	
ORDER NO.:		NO OFF:	ONE (1)
SCALE:	N.T.S.	CAD REF:	JS-GST-SC-S

FIBRETANK SYSTEMS		PT Y LIMITED	
P O BOX 102		CARRINGTON N.S.W. 2294	
PHONE (02) 4961-2745		FAX: (02) 4962-2812	
THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED			
TITLE:		GENERAL ARRANGEMENT T42	
GLASTEEL II U/G STORAGE VESSEL (6mm SHELL)		VESSEL CLASS	
ESTIMATE NUMBER:		DRAWING NUMBER:	
N/A		JS 042000-000	
JOB No.:		SHEET: 1 of 1	
		REVISION: B	
		SHEET SIZE	
		A3	