



F5	RUST RED FLOWCOAT	-
F4	GLASS OWENN'S CORNINS 360 RR	-
F3	CATALYST	-
F2	AROPOL 7241PS/PW	-
F1	TEXOPRINT MAT	-
ITEM	DESCRIPTION	WEIGHT
FIBREGLASS		

NOTE:

- 1: VACUUM ON INTERSTITIAL SPACE IS FACTORY SET & GAUGE SET
- 2: INSTALLATION AS PER GLASTEEL II INSTALLATION INSTRUCTIONS & APPLICABLE CODES
- 3: VESSEL IDENTIFICATION No. & MANUFACTURE DATE ARE LAMINATED TO TOP OF VESSEL
- 4: VESSEL MANUFACTURED TO AS1692
- 5: PLASTIC LIFTING LUG COVERS SUPPLIED WITH VESSEL
- 6: HOLD DOWN STRAPS POSITION ARE TO BE MARKED ON VESSEL DURING MANUFACTURING
- 7: ALL SOCKETS TO BE CLEANED AND FITTED WITH PLASTIC DUST CAPS
- 8: 6mm STRIKER PLATES TO BE FITTED UNDER ALL OPENINGS
- 9: ALL GRC JOINTS TO BE JOGGLED
- 10: VOLUME = 72,700 L (APPROX)
- 11: WEIGHT OF TANK = 6,180 kg (APPROX)

No.	REVISION DETAILS	BY	DATE	CLIENT:
F				FTS STD
E				DRAWN: V.B.B.
D				CHECKED:
C				APPROVED:
B				ORDER No:
A	ORIGINAL ISSUE			SCALE: N.T.S.

JOB No:		SHEET: 1 of 1		REVISION: A
ESTIMATE NUMBER:		DRAWING NUMBER:		SHEET SIZE
N/A		JS 070000-000		A3
TITLE: GENERAL ARRANGEMENT T70				
GLASTEEL II U/G STORAGE VESSEL (6mm SHELL)				
FIBRETEK SYSTEMS				
PTY LIMITED				
PO BOX 102				
CARRINGTON N.S.W. 2294				
PHONE (02) 4961-2745				
FAX (02) 4962-2812				
THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETEK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETEK SYSTEMS Pty LIMITED				
ITEM	QTY	DESCRIPTION	PART / SUB ASSM No.	
12	5	STRIKER PLATE	SUB1047	
11	2	50NB MONITOR SOCKET C/W INTERNAL PIPE	SUB1082	
10	2	LIFTING LUG - 5 TONNE C/W DOUBLER PAD	SUB1076	
9	2	END D & F SLIP IN 2750 ID x 6 PLATE	SUB1075	
8	3	SHELL Ø2750 ID x 6 PLATE x 3000 LONG	SUB1039	
7	1	100NB PHOENIX FLANGE	006395	
6	1	100NB PHOENIX FLANGE	006395	
5	1	100NB FILL SOCKET C/W PIPE	SUB1057	
4	1	80NB DIP SOCKET C/W PIPE	SUB1052	
3	1	100NB PHOENIX FLANGE	006395	
2	1	100NB PHOENIX FLANGE	006395	
1	1	100NB PHOENIX FLANGE	006395	

Dimension in millimetres to be to the applicable design code of manufacture, and/or client requirement.