



- NOTE:**
- VESSEL IS MANUFACTURED TO AS 1692 AND AIR TESTED TO 35kPa
  - LADDER & PLATFORM WILL BE AS SHOWN UNO. BY CUSTOMER
  - ALL WELDS AS PER AS1554 GP-1 (IND.T. - VISUAL)
  - VESSEL VOLUME = 16,500 L (S.F.L. - 15,800 L)
  - VESSEL WEIGHT = 3,600 kg

**SURFACE FINISH**  
 INTERNAL - CLEAN AND DRY  
 EXTERNAL - SANDBLAST & 1 COAT (2 PAC EPOXY)  
 AMERLOCK 2 - DFT 150 MICRONS (WHITE)  
 LADDER & PLATFORM  
 - HOT DIP GALVANISED

ITEM	QTY	DESCRIPTION	SIZE	TYPE	REMARKS	PART/SUB No.
12	1	EMERGENCY VENTING	200NB	-	INTERSTITIAL SPACE EMERGENCY VENT & FREE VENT	SUB-2117
11	-	-	-	-	-	-
10	-	-	-	-	-	-
9	1	FILL LINE	80NB	-	C/W OVER FILL PROTECTION DEVICE	SUB2121/SUB1353
8	1	VENT (TANK)	80NB	SOCKET	C/W FREE VENT (015045)	SUB-1346
7	1	MONITOR	50NB	-	-	SUB-1347
6	-	-	-	-	-	-
5	-	-	-	-	-	-
4	1	SUCTION	50NB	SOCKET	C/W PIPE ANTI-SYPHON VALVE & 50NB TABLE 'T' FLANGE	SUB-1344
3	1	DIP	50NB	SOCKET	C/W INTERNAL PIPE & CALIBRATED DIP STICK	SUB-1050
2	1	LEVEL SENSOR	50NB	SOCKET	PLUGGED (006200)	006145
1	1	EMERGENCY VENT	200NB	-	STD EMERGENCY VENT	SUB-2114

No.	REVISION DETAILS	BY	DATE	CLIENT:	FTS STD
F				DRAWN: V.B.B.	DATE: 7-7-03
E				CHECKED:	DATE:
D				APPROVED:	DATE:
C				ORDER No:	No OFF: ONE (1)
B				SCALE: 1:40	CAD REF: SW-Steel-Wrap
A	ORIGINAL ISSUE	0	0	All tolerancing to be to the applicable design code of manufacture, and/or client requirement.	

  

JOB No:		ESTIMATE NUMBER: N/A		DRAWING NUMBER: SW 015000-001		SHEET: 1 of 1		REVISION: A	
TITLE: GENERAL ARRANGEMENT STATIC T15 WRAPPED BUNDED VESSEL				VESSEL CLASS: N/A		SHEET SIZE: A3			

  

FIBRETEK SYSTEMS PTY LIMITED		PO BOX 102 CARINGTON N.S.W. 2294 PHONE (02) 4961-2745 FAX (02) 4962-2812		THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETEK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETEK SYSTEMS PTY LIMITED	
------------------------------	--	--	--	--	--