



EQUIPMENT No 00-OWS-1

ITEM	QTY	DESCRIPTION
16	1	50NB 150 lb ANSI FLANGE - LEVEL GAUGE
15	1	50NB 150 lb ANSI FLANGE - SAMPLING POINT
14	1	50NB 150 lb ANSI FLANGE - WASTE OIL PUMPOUT
13	1	50NB 150 lb ANSI FLANGE - OIL/WATER INTERFACE LEVEL SENSOR
12	1	50NB VENT C/W 600 micron GAUZE
11	1	50NB 150 lb ANSI FLANGE - EFFLUENT DOWNCOMER PIPE
10	1	OIL / WATER SEPARATOR CHAMBER C/W COALESCER PLATES
9	1	SLUDGE BAFFLE
8	1	INLET FLUID DIFFUSER BAFFLE
7	1	100NB 150 lb ANSI FLANGE - OUTLET
6	1	100NB 150 lb ANSI FLANGE - INLET
5	2	SUPPORT CRADLES - FTS STANDARD
4	2	LIFTING LUGS - 5.0 TONNE ea C/W DOUBLER PLATE
3	2	600NB TOP ACCESS MANHOLE
2	1	SHELL 2190 x 4200 x 8 PLATE
1	2	ENDS DISHED & FLANGED 2190 x 8 PLATE

NOTES:

- 1: VESSEL MANUFACTURED TO AS1692 & AIR TESTED TO 35 kPa.
- 2: VESSEL EMPTY WEIGHT = 5500 kgs.
- 3: TOTAL VOLUME = 16,300 Ltrs

SURFACE FINISH:

INTERNAL - SANDBLASTED TO AS1627-4 CLASS 2.5 FOLLOWED BY:  
 3 x 100 micron COATS OF WATTYL PHENGARD (WHITE)  
 EXTERNAL - SANDBLASTED TO AS1627-4 CLASS 2.5 FOLLOWED BY:  
 1 x 75 micron COAT OF INTERNATIONAL INTERZINC 42  
 1 x 125 micron COAT OF INTERNATIONAL INTERCURE 420  
 1 x 75 micron COAT OF INTERNATIONAL INTERTHANE 990 (WHITE)

No.	REVISION DETAILS	BY	DATE	CLIENT:
F				CH2M HILL
E				DRAWN: TAH DATE: 26-06-08
D				CHECKED: DATE:
C				APPROVED: DATE:
B				ORDER No: No OFF: ONE (1)
A	ORIGINAL ISSUE	0	0	SCALE: 1:40 CAD REF: SW-Steel-Wrap

Dimension in millimetres  
 All tolerancing to be to the applicable design code of manufacture,  
 and/or client requirement.

FIBRETANK SYSTEMS PTY LIMITED		PO BOX 102 CARRINGTON N.S.W. 2294 PHONE (02) 4961-2745 FAX: (02) 4962-2812	THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED
TITLE: GENERAL ARRANGEMENT DOUBLE WALL T15 O/G OIL / WATER SEPARATOR VESSEL			VESSEL CLASS N/A
ESTIMATE NUMBER: N/A	DRAWING NUMBER: SW 015000-004		SHEET SIZE A3
JOB No:	SHEET: 1 of 1	REVISION: A	