



NOTE:
 1: ALL INLET AND OUTLET PIPE WORK TO BE STAINLESS STEEL SCH40
 2: ALL VENT TO HAVE 5 MICRON GAUZE
 3: REFER TO SUB-1343 FOR CONTAINMENT BOX DETAILS
 4: REFER TO SUB-1076 FOR LIFTING LUG DETAILS C/W COMP PLATE
 5: REFER TO SUB-1027 FOR CRADLE DETAILS
 6: REFER TO SUB-1050 FOR DIP PIPE DETAILS
 7: LADDER AND PLATFORM WILL BE AS SHOWN U.N.O. BY CUSTOMER
 8: ALL WELDS AS PER AS1554. GP-1 (N.D.T.- VISUAL)
 9: APPROX VESSEL VOLUME - 21,000 L (S.F.L.= 20,200 L)
 10: APPROX VESSEL WEIGHT - 4600 kg

SURFACE FINISH
 INTERNAL - BLAST AND CLEAN
 EXTERNAL - SANDBLAST & 1 COAT (2 PAC EPOXY)
 AMERLOCK 2 - DFT 150 microns (WHITE)
LADDER & PLATFORM
 - HOT DIP GALVANISED

ITEM	QTY	DESCRIPTION	SIZE	TYPE	REMARKS	PART/SUB No.
12	1	EMERGENCY VENTING	200NB	-	INTERSTITIAL SPACE EMERGENCY VENT C/W FREE VENT	-
11	1	CABLE ENTRY	40NB	-	-	SUB-1345
10	1	FILL LINE ACCESSORIES	50NB	-	-	SUB-1356
9	1	FILL LINE	80NB	-	C/W OVER FILL PROTECTION DEVICE	SUB2121/SUB1353
8	1	VENT (TANK)	80NB	SOCKET	C/W FREE VENT (015045)	SUB-1346
7	1	MONITOR	50NB	-	INTERSTICE MONITOR	SUB-1347
6	1	DRAIN	50NB	HALF SOCKET	PLUGGED (006200)	006096
5	2	PUMP SUPPORT	-	-	-	SUB1223
4	2	SUCTION	50NB	SOCKET	C/W PIPE, ANTI-SYPHON VALVE & TERMINATED AT 50NB SOCKET	-
3	1	ULTRASONIC LEVEL	100NB	ANSI S.O/R.F	C/W BLIND FLANGE	-
2	1	LEVEL SENSOR	50NB	SOCKET	PLUGGED (006200)	006145
1	1	600NB MANWAY	600NB	-	C/W FTS STD EMERGENCY VENT	SUB-2114

No.	REVISION DETAILS	BY	DATE
F			
E			
D	FILL LINE INTERNAL PIPE ALTERED	V.B.B.	25-07-03
C	SUCTION LINE SOCKETS NOW TO BE WELDED TO VERANDAH	V.B.B.	25-03-03
B	SUCTION LINE UPDATED	V.B.B.	25-03-03
A	ORIGINAL ISSUE	0	0

CLIENT: **FTS STD**
 DRAWN: V.B.B. DATE: 12-07-01
 CHECKED: DATE:
 APPROVED: DATE:
 ORDER No: No OFF: ONE (1)
 SCALE: 1:40 CAD REF: SW-Steel-Wrap
 Dimension in millimetres
 All tolerancing to be to the applicable design code of manufacture,
 and/or client requirement.

FIBRETANK SYSTEMS PTY LIMITED
 PO BOX 102 CARRINGTON N.S.W. 2294
 PHONE (02) 4961-2745 FAX: (02) 4962-2812

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED

TITLE: **GENERAL ARRANGEMENT T20 WRAPPED BUNDED VESSEL (EMULSION TANK)**

ESTIMATE NUMBER: N/A DRAWING NUMBER: SW 020000-004

JOB No: SHEET: 1 of 1 REVISION: D

VESSEL CLASS: N/A SHEET SIZE: A3