



NOTE:

- 1: VESSEL IS MANUFACTURED TO AS 1692 AND AIR TESTED TO 35kPa
- 2: LADDER & PLATFORM WILL BE AS SHOWN U.N.O. BY CUSTOMER
- 3: ALL WELDS AS PER AS1554 GP-1 (N.D.T. - VISUAL)
- 4: VESSEL VOLUME = 23,100 L (S.F.L. - 22,400 L)
- 5: VESSEL WEIGHT = 9,800 kg

SURFACE FINISH

- INTERNAL - CLEAN AND DRY
- EXTERNAL - SANDBLAST & 1 COAT (2 PAC EPOXY) AMERLOCK 2 - DFT 150 microns (WHITE)
- LADDER & PLATFORM - HOT DIP GALVANISED

12	1	EMERGENCY VENTING	200NB	-	INTERSTITIAL SPACE EMERGENCY VENT	SUB-2117
11	-	-	-	-	-	-
10	-	-	-	-	-	-
9	1	FILL LINE	80NB	-	C/W OVER FILL PROTECTION DEVICE	SUB2121/SUB1353
8	1	VENT (TANK)	80NB	SOCKET	C/W FREE VENT (Ø150x45)	SUB-1346
7	1	MONITOR	65NB	-	C/W FREE VENT 50NB SOCKET & PIPE (ELECTRONIC MONITOR)	SUB-1347
6	-	-	-	-	-	-
5	-	-	-	-	-	-
4	1	SUCTION	50NB	SOCKET	C/W PIPE, ANTI-SYPHON VALVE & 50NB TABLE 'E' FLANGE	SUB-1344
3	1	DIP	50NB	SOCKET	C/W INTERNAL PIPE & CALIBRATED DIP STICK	SUB-1050
2	1	LEVEL SENSOR	50NB	SOCKET	PLUGGED (Ø06200)	006145
1	1	EMERGENCY VENT	200NB	-	STD EMERGENCY VENT	SUB-2114
ITEM	QTY	DESCRIPTION	SIZE	TYPE	REMARKS	PART/SUB No.

No.	REVISION DETAILS	BY	DATE	CLIENT:	FIBRETANK SYSTEMS PTY LIMITED	PO BOX 102 CARRINGTON N.S.W. 2294 PHONE (02) 4961-2745 FAX: (02) 4962-2812	THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED	
F				FTS STD				
E				DRAWN: V.B.B.	DATE: 12-07-01			
D				CHECKED:	DATE:			
C				APPROVED:	DATE:			
B				ORDER No:	No OFF: ONE (1)			
A	ORIGINAL ISSUE	0	0	SCALE: 1:40	CAD REF: SW-Steel-Wrap	ESTIMATE NUMBER: N/A	DRAWING NUMBER: SW 020000-006	
				Dimension in millimetres All tolerancing to be to the applicable design code of manufacture, and/or client requirement.		JOB No:	SHEET: 1 of 1	REVISION: A
					GENERAL ARRANGEMENT STATIC T20 WRAPPED BUNDED VESSEL		VESSEL CLASS N/A	
							SHEET SIZE A3	