



- NOTE:
- 1: VESSEL IS MANUFACTURE TO AS1692 AND AIR TESTED TO 35 kPa
 - 2: LADDER AND PLATFORM WILL BE AS SHOWN UNO BY CUSTOMER.
 - 3: ALL WELDS AS PER AS1554. GP-1 (N.D.T.- VISUAL)
 - 4: APPROX VESSEL VOLUME - 27,800 L (S.F.L.= 26,800 L)
 - 5: APPROX VESSEL WEIGHT - 5700 kg

SURFACE FINISH
 INTERNAL - CLEAN AND DRY
 EXTERNAL - SANDBLAST & 1 COAT (2 PAC EPOXY)
 AMERLOCK 2 - DFT 150 microns (WHITE)
 LADDER & PLATFORM
 - HOT DIP GALVANISED

ITEM	QTY	DESCRIPTION	SIZE	TYPE	REMARKS	PART/SUB No.
12	1	MANWAY	600NB	-	FTS STD	-
11	1	EMERGENCY VENTING	200NB	-	INTERSTITIAL SPACE EMERGENCY VENT C/W FREE VENT	SUB-1345
10						
9	1	FILL LINE	80NB	-	C/W 2" OVER FILL PROTECTION (100NB TANK ENTRY)	SUB2121/SUB1353
8	1	VENT (TANK)	80NB	SOCKET	C/W FREE VENT (015045)	SUB-1346
7	1	MONITOR	50NB	-	INTERSTICE MONITOR	SUB-2530
6						
5						
4	1	SUCTION	50NB	SOCKET	C/W PIPE, ANTI-SYPHON VALVE & 50NB TABLE 'E' FLANGE	SUB-1344
3	1	DIP	50NB	SOCKET	C/W INTERNAL PIPE & CALIBRATED DIP STICK	SUB-1050
2						
1	1	EMERGENCY VENT	200NB	-	STD EMERGENCY VENT	SUB-2114

No.	REVISION DETAILS	BY	DATE	CLIENT:	FIBRETANK SYSTEMS PTY LIMITED	PO BOX 102 CARRINGTON N.S.W. 2294 PHONE (02) 4961-2745 FAX: (02) 4962-2812	THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED	VESSEL CLASS
F				DRAWN: V.B.B.	DATE: 20-10-03	TITLE: GENERAL ARRANGEMENT T25 STATIC WRAPPED BUNDED VESSEL		N/A
E				CHECKED:	DATE:	ESTIMATE NUMBER: N/A		SHEET SIZE A3
D				APPROVED:	DATE:	DRAWING NUMBER: SW 025000-004		
C				ORDER No:	No OFF: ONE (1)	SHEET: 1 of 1		REVISION: A
B				SCALE: 1:50	CAD REF:	JOB No:		
A	ORIGINAL ISSUE	0	0	Dimension in millimetres All tolerancing to be to the applicable design code of manufacture, and/or client requirement.				