



NOTE:

- 1: VESSEL IS MANUFACTURE TO AS1692 AND AIR TESTED TO 35kPa
- 2: ALL WELDS AS PER AS1554 GP-1 (N.D.T. - VISUAL)
- 3: VESSEL VOLUME = 29,100 L (S.F.L. - 28,200 L)
- 4: VESSEL WEIGHT = 6,600 kg

SURFACE FINISH

INTERNAL - CLEAN AND DRY
 EXTERNAL - SANDBLAST & 1 COAT (2 PAC EPOXY)
 AMERLOCK 2 - DFT 150 microns (WHITE)

LADDER & PLATFORM

- HOT DIP GALVANISED

ITEM	QTY	DESCRIPTION	SIZE	TYPE	REMARKS	PART/SUB No.
12	1	EMERGENCY VENTING	200NB	-	INTERSTITIAL SPACE EMERGENCY VENT C/W FREE VENT	SUB-2117
11	-	-	-	-	-	-
10	-	-	-	-	-	-
9	1	FILL LINE	80NB	-	MECHANICAL OVER FILL PROTECTION DEVICE OPTIONAL	SUB2119/SUB1358
8	1	VENT (TANK)	80NB	SOCKET	C/W FREE VENT (015041)	SUB-1349
7	1	MONITOR	50NB	-	C/W ELECTRONIC MONITOR OPTIONAL	SUB-2108
6	-	-	-	-	-	-
5	-	-	-	-	-	-
4	1	SUCTION	50NB	SOCKET	C/W PIPE, ANTI-SYPHON VALVE & 50NB TABLE 'E' FLANGE	SUB1218/SUB1220
3	1	DIP	80NB	SOCKET	C/W INTERNAL PIPE	SUB-1052
2	1	LEVEL SENSOR	50NB	SOCKET	C/W OVERFILL ELECTRONIC MONITOR	006145
1	1	MANWAY	600NB	-	C/W 200NB EMERGENCY VENT	-

No.	REVISION DETAILS	BY	DATE	CLIENT:	FIBRETANK SYSTEMS PTY LIMITED	PO BOX 102 CARRINGTON N.S.W. 2294 PHONE (02) 4961-2745 FAX: (02) 4962-2812	THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED	VESSEL CLASS
F				—				
E				DRAWN: V.B.B.	DATE: 15-11-02			
D				CHECKED:	DATE:			
C				APPROVED:	DATE:			
B				ORDER No:	No OFF: ONE (1)			
A	ORIGINAL ISSUE	0	0	SCALE: 1:50	CAD REF: SW-Steel-Wrap	ESTIMATE NUMBER: N/A	DRAWING NUMBER: SW 03000-001	SHEET SIZE A3
				Dimension in millimetres All tolerancing to be to the applicable design code of manufacture, and/or client requirement.		JOB No:	SHEET: 1 of 1	REVISION: A

TITLE: GENERAL ARRANGEMENT
T30 STATIC WRAPPED BUNDED VESSEL