



- NOTE:
- 1: VESSEL IS MANUFACTURE TO AS1692 AND AIR TESTED TO 35 kPa
 - 2: LADDER AND PLATFORM WILL BE AS SHOWN U.N.O. BY CUSTOMER
 - 3: ALL WELDS AS PER AS1554, GP-1 (N.D.T. - VISUAL)
 - 4: APPROX VESSEL VOLUME - 50,500 L (S.F.L. = 48,800 L)
 - 5: APPROX VESSEL WEIGHT - 9200 kg

SURFACE FINISH
 INTERNAL - CLEAN AND DRY
 EXTERNAL - PAINT MIN D.F.T. 150 MICRONS
 LADDER & PLATFORM
 - HOT DIP GALVANISED

ITEM	QTY	DESCRIPTION	SIZE	TYPE	REMARKS	PART/SUB No.
11	1	EMERGENCY VENTING	200NB	-	INTERSTITIAL SPACE EMERGENCY VENT C/W FREE VENT	SUB-1345
10	1	CABLE ENTRY	40NB	-	-	SUB-1356
9	1	FILL LINE	80NB	-	C/W 4" OVER FILL PROTECTION (150NB TANK ENTRY)	-
8	1	VENT (TANK)	80NB	SOCKET	C/W FREE VENT (015045)	SUB-1346
7	1	MONITOR	50NB	-	INTERSTICE MONITOR	SUB-2530
6	1	DRAIN	50NB	HALF SOCKET	PLUGGED (006200)	006096
5	1	PUMP SUPPORT	-	-	-	SUB1223
4	1	SUCTION	50NB	SOCKET	C/W PIPE, ANTI-SYPHON VALVE & 50NB TABLE 'E' FLANGE	SUB-1344
3	1	DIP	50NB	SOCKET	C/W INTERNAL PIPE & CALIBRATED DIP STICK	SUB-1050
2	1	LEVEL SENSOR	50NB	SOCKET	PLUGGED (006200)	006145
1	1	EMERGENCY VENT	200NB	-	STD EMERGENCY VENT	SUB-2114

No.	REVISION DETAILS	BY	DATE
F			
E			
D			
C			
B			
A	ORIGINAL ISSUE	0	0

CLIENT:	FIBRETANK SYSTEMS Pty Ltd		
DRAWN:	V.B.B.	DATE:	03-09-03
CHECKED:		DATE:	
APPROVED:		DATE:	
ORDER No:		No OFF:	ONE (1)
SCALE:	N.T.S.	CAD REF:	

TITLE:	FIBRETANK SYSTEMS GENERAL ARRANGEMENT		
ESTIMATE NUMBER:	150 WRAPPED BUNDED STORAGE VESSEL		
JOB No:	N/A	DRAWING NUMBER:	SW 050000-001
SHEET:	1 of 1	REVISION:	A

PO BOX 102 CARINGTON N.S.W. 2294 PHONE (02) 4961-2745 FAX: (02) 4962-2812	THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED
--	--

Dimension in millimetres
 All tolerancing to be to the applicable design code of manufacture, and/or client requirement.