



- NOTE:
- 1: VESSEL IS MANUFACTURE TO AS1692 AND AIR TESTED TO 35 kPa
  - 2: LADDER AND PLATFORM WILL BE AS SHOWN U.N.O. BY CUSTOMER
  - 3: ALL WELDS AS PER AS1554. GP-1 (N.D.T.- VISUAL)
  - 4: APPROX VESSEL VOLUME - 64,100 L (S.F.L.= 62,000 L)
  - 5: APPROX VESSEL WEIGHT - 11,000 kg

**SURFACE FINISH**  
 INTERNAL - CLEAN AND DRY  
 EXTERNAL - SANDBLAST & 1 COAT (2 PAC EPOXY)  
 AMERLOCK 2 - DFT 150 microns (WHITE)

LADDER & PLATFORM  
 - HOT DIP GALVANISED

ITEM	QTY	DESCRIPTION	SIZE	TYPE	REMARKS	PART/SUB No.
11	1	EMERGENCY VENTING	200NB	-	INTERSTITIAL SPACE EMERGENCY VENT C/W FREE VENT	SUB-1345
10	1	CABLE ENTRY	40NB	-	-	SUB-1356
9	1	FILL LINE	80NB	-	C/W 4" OVER FILL PROTECTION (150NB TANK ENTRY)	SUB2121/SUB1353
8	1	VENT (TANK)	80NB	SOCKET	C/W FREE VENT (015045)	SUB-1346
7	1	MONITOR	50NB	-	INTERSTICE MONITOR	SUB-2530
6	1	DRAIN	50NB	HALF SOCKET	PLUGGED (006200)	006096
5	1	PUMP SUPPORT	-	-	-	SUB1223
4	1	SUCTION	50NB	SOCKET	C/W PIPE, ANTI-SYPHON VALVE & 50NB TABLE 'E' FLANGE	SUB-1344
3	1	DIP	50NB	SOCKET	C/W INTERNAL PIPE & CALIBRATED DIP STICK	SUB-1050
2	1	LEVEL SENSOR	50NB	SOCKET	PLUGGED (006200)	006145
1	1	EMERGENCY VENT	200NB	-	STD EMERGENCY VENT	SUB-2114

No.	REVISION DETAILS	BY	DATE	CLIENT:	FIBRETANK SYSTEMS PTY LIMITED	PO BOX 102 CARRINGTON N.S.W. 2294 PHONE (02) 4961-2745 FAX: (02) 4962-2812	THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED
F				DRAWN: V.B.B.	DATE: 8-10-03	TITLE: GENERAL ARRANGEMENT	
E				CHECKED:	DATE:	T60 WRAPPED BUNDED STORAGE VESSEL	
D				APPROVED:	DATE:	ESTIMATE NUMBER: N/A	VESSEL CLASS N/A
C				ORDER No:	No OFF: ONE (1)	DRAWING NUMBER: SW 060000-001	SHEET SIZE A3
B				SCALE: N.T.S.	CAD REF:	JOB No:	SHEET: 1 of 1
A	ORIGINAL ISSUE	0	0	Dimension in millimetres All tolerancing to be to the applicable design code of manufacture, and/or client requirement.		REVISION: A	