



- NOTE:
- REFER TO SHEET 2 FOR TANK & OUTER SHELL DETAILS
 - REFER TO SHEET 3 FOR OUTER SHROUD DETAILS
 - REFER TO SUB-1343 FOR CONTAINMENT BOX DETAILS
 - REFER TO SUB-1077 FOR LIFTING LUG DETAILS C/W COMP PLATE
 - REFER TO SUB-2407 FOR CRADLE DETAILS
 - REFER TO SUB-1052 FOR DIP PIPE DETAILS
 - LADDER & PLATFORM WILL BE AS DRAWN U.N.O. BY CUSTOMER
 - ALL WELDS AS PER AS1554. GP-1 (N.D.T.- VISUAL)
 - VESSEL VOLUME = 72,400 L (S.F.L = 71,000 L)
 - VESSEL WEIGHT = 14200 kg

SURFACE FINISH
 INTERNAL - CLEAN AND DRY
 EXTERNAL - SANDBLAST & 1 COAT (2 PAC EPOXY)
 AMERLOCK 2 - DFT 150 microns (WHITE)

LADDER & PLATFORM
 - HOT DIP GALVANISED

| ITEM | QTY | DESCRIPTION | SIZE | TYPE | REMARKS | PART/SUB No. |
|------|-----|-----------------------|-------|-------------|--|-----------------|
| 12 | 1 | EMERGENCY VENTING | 200NB | - | INTERSTITIAL SPACE EMERGENCY VENT | SUB-2117 |
| 11 | 1 | CABLE ENTRY | 40NB | - | - | SUB-1345 |
| 10 | 1 | FILL LINE ACCESSORIES | 80NB | - | - | SUB-1357 |
| 9 | 1 | FILL LINE | 80NB | - | OPW 61f-STOP 3050 OVER FILL PROTECTION DEVICE OPTIONAL | - |
| 8 | 1 | VENT (TANK) | 80NB | SOCKET | C/W FREE VENT (Ø15041) | SUB-1349 |
| 7 | 1 | MONITOR / VENT | 80NB | - | C/W FREE VENT 50NB SOCKET & PIPE (ELECTRONIC MONITOR) | SUB2108 |
| 6 | 1 | DRAIN | 50NB | HALF SOCKET | PLUGGED (006200) | 006225 |
| 5 | 1 | PUMP SUPPORT | - | - | - | SUB1223 |
| 4 | 2 | SUCTION | 50NB | SOCKET | C/W PIPE, 50NB ANTI-SYPHON VALVE & TABLE 'E' FLANGE | SUB1218/SUB1220 |
| 3 | 1 | DIP | 80NB | SOCKET | C/W INTERNAL PIPE | SUB-1052 |
| 2 | 1 | LEVEL SENSOR | 50NB | SOCKET | C/W ELECTRONIC OVERFILL MONITOR | - |
| 1 | 1 | MANWAY | 600NB | - | C/W STD EMERGENCY VENT | - |

| No. | REVISION DETAILS | BY | DATE |
|-----|--------------------------|--------|----------|
| F | | | |
| E | | | |
| D | | | |
| C | | | |
| B | ELECTRONIC MONITOR ADDED | V.B.B. | 19-11-01 |
| A | ORIGINAL ISSUE | 0 | 0 |

CLIENT: **FTS STD**

DRAWN: V.B.B. DATE: 12-07-01

CHECKED: DATE:

APPROVED: DATE:

ORDER No: No OFF: ONE (1)

SCALE: 1:50 CAD REF: SW-Steel-Wrap

Dimension in millimetres
 All tolerancing to be to the applicable design code of manufacture,
 and/or client requirement.

FIBRETANK SYSTEMS PTY LIMITED

PO BOX 102
 CARRINGTON N.S.W. 2294
 PHONE (02) 4961-2745
 FAX: (02) 4962-2812

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

TITLE: **GENERAL ARRANGEMENT
 T70 WRAPPED BUNDED VESSEL ON SKID**

ESTIMATE NUMBER: N/A DRAWING NUMBER: SW 070000-001

JOB No: SHEET: 1 of 1 REVISION: A

VESSEL CLASS: N/A SHEET SIZE: A3