



NOTES:

- 1. VESSEL TO BE MANUFACTURED TO AS1692 AND AIR TESTED TO 35kPa
- 2. WEIGHT: 9500 Kg (APPROX)
- 3. VOLUME: 116580 Litres (APPROX)
- 4. DIP PIPE SUPPLIED WITH 1m EXTENSION PIPE (THREADED EACH END)

SURFACE FINISH:

INTERNAL - CLEAN AND DRY
EXTERNAL - PAINT MIN DFT 150 MICRONS (BLAST IS OPTIONAL EXTRA)

ITEM	QTY	DESCRIPTION	PART / SUB ASSM No.
11	2	LIFTING LUGS - 5 TONNE C/W DOUBLER PAD	
10	1	600NB ACCESS MANHOLE	
9	1	80NB 1501b ANSI FLANGED (OUTLET)	
8	1	2" BSP SOCKET C/W INTERNAL PIPE	(LEVEL SENSOR)
7	1	2" BSP SOCKET C/W INTERNAL PIPE (DIP)	
6	1	100NB 1501b ANSI FLANGE C/W PIPE	(FILL)
5	1	3" BSP SOCKET (VENT)	
4	1	50NB 1501b ANSI FLANGE (DRAIN)	
3	2	3462 CRADLES/SADDLE PLATE	
2	2	ENDS D & F SLIP IN 3462 x 8 THK	
1	4	SHELL: 3462 ID x 8PL x 3000 LONG	

No.	QTY	DESCRIPTION	PART / SUB ASSM No.
A2	1	TOUCH UP PAINT	-
A1	1	DIPSTICK T110	SUB1073
ACCESSORIES			PART / SUB ASSM No.

No.	REVISION DETAILS	BY	DATE	CLIENT:
F				BRICON Pty Ltd
E				DRAWN: T.A.H. DATE: 07-08-06
D				CHECKED: DATE:
C	MANHOLE NOTE ADDED - REF DIM A	T.A.H	30-8-06	APPROVED: DATE:
B	NOZ 8 PIPE ADDED + N5,7,8 & 10 MOVED	B	10-8-06	ORDER No: No OFF: ONE (1)
A	ORIGINAL ISSUE	0	0	SCALE: 1:50 CAD REF: SA-Steel-AG

Dimension in millimetres
All tolerancing to be to the applicable design code of manufacture, and/or client requirement.

ITEM	QTY	DESCRIPTION	PART / SUB ASSM No.
FIBRETANK SYSTEMS PTY LIMITED		PO BOX 102 CARRINGTON N.S.W. 2294 PHONE (02) 4961-2745 FAX: (02) 4962-2812	THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED
TITLE: GENERAL ARRANGEMENT T110 A/G STORAGE VESSEL (8mm SHELL)			VESSEL CLASS N/A
ESTIMATE NUMBER: N/A		DRAWING NUMBER: SA 110000-005	SHEET SIZE A3
JOB No:		SHEET: 1 of 1	REVISION: C