



- NOTES:**
1. VESSEL TO BE MANUFACTURED TO AS1692 AND AIR TESTED TO 35kPa
 2. WEIGHT: 1730 Kg (APPROX)
 3. VOLUME: 16480 Litres (APPROX)
 4. PLATFORM WILL BE AS SHOWN UNLESS NOMINATED OTHERWISE BY CUSTOMER

SURFACE FINISH:
 INTERNAL - CLEAN AND DRY
 EXTERNAL - ABRASIVE BLAST TO AS1627-4, CLASS 2.4, FOLLOWED BY
 1st COAT - 75um INTERZINC 42
 2nd COAT - 125um INTERGUARD 475
 3rd COAT - 75um INTERTHANE 990 (WHITE)

ITEM	QTY	DESCRIPTION	SIZE	TYPE	REMARKS	PART/SUB No.
7	1	DRAIN	50NB	SOCKET	-	-
6	1	OUTLET	50NB	150# ANSI	-	-
5	1	FLANGE	50NB	150# ANSI	-	-
4	1	VENT	80NB	SOCKET	-	-
3	1	SOCKET	100NB	SOCKET	-	-
2	1	DIP	50NB	SOCKET	C/W INTERNAL PIPE & CALIBRATED DIP STICK	-
1	1	MANWAY	600NB	-	STD FITS MANWAY	-

No.	REVISION DETAILS	BY	DATE	CLIENT:	DATE:	DATE:	DATE:	TITLE:	ESTIMATE NUMBER:	DRAWING NUMBER:	SHEET:	REVISION:	VESSEL CLASS	SHEET SIZE
A	ORIGINAL ISSUE			FIBRETANK SYSTEMS Pty Ltd	4-8-04	4-8-04	4-8-04	GENERAL ARRANGEMENT TANK 5 & 6	N/A	SA 015000-002	1 of 1	C	N/A	A3
B	ITEM 5 & 6 UPDATED FROM TABLE FLANGES	V.B.B.	17-8-04	FIBRETANK SYSTEMS Pty Ltd				15,000 LITRE ONGROUND STEEL STORAGE TANK						
C	ITEM 6 MOVED	V.B.B.	18-8-04											
D														
E														
F														

CLIENT: FIBRETANK SYSTEMS Pty Ltd
DRAWN: V.B.B.
CHECKED:
APPROVED:
ORDER No.:
SCALE: 1:30
CAD REF: SA-Steel-AG

PO BOX 102
CARRINGTON N.S.W. 2294
PHONE (02) 4961-2745
FAX (02) 4962-2812

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED

REVISIONS:

Dimension in millimetres and/or client requirement.

Dimension in millimetres and/or client requirement.