



NOTES:

- 1. VESSEL TO BE MANUFACTURED TO AS1692 AND AIR TESTED TO 35kPa
- 2. WEIGHT: 700 Kg (APPROX)
- 3. VOLUME: 5100 Litres (APPROX)
- 4. STAIRS WILL BE AS SHOWN UNLESS NOMINATED OTHERWISE BY CUSTOMER

SURFACE FINISH:

INTERNAL - CLEAN AND DRY
 EXTERNAL - PAINT MIN DFT 150 MICRONS COLOUR GOLDEN TAN X53

8	1	SUPPLY	50NB	-	SOCKET	-
8	1	MANWAY	600NB	-	-	-
7	1	FUEL LEVEL	50NB	-	SOCKET	SENSOR AND ALARM BY OTHERS
6	1	DRAIN	25NB	-	SOCKET	C/W PLUG
5	1	VENT	50NB	-	SOCKET	-
4	1	SUCTION	80NB	-	SOCKET	INTERNAL PIPE BY OTHERS
3	1	RETURN	50NB	-	SOCKET	C/W INTERNAL PIPE
2	1	DIP	50NB	-	SOCKET	C/W INTERNAL PIPE & CALIBRATED HINGED DIP STICK
1	1	FILL	50NB	-	SOCKET	-

ITEM	QTY	DESCRIPTION	SIZE	SCH	TYPE	REMARKS
------	-----	-------------	------	-----	------	---------

A2	1	TOUCH UP PAINT	-
A1	1	DIPSTICK T5	SUB1019
ACCESSORIES			PART / SUB ASSM No.

No.	REVISION DETAILS	BY	DATE	CLIENT:	FIBRETANK SYSTEMS PTY LIMITED	PO BOX 102 CARRINGTON N.S.W. 2294 PHONE (02) 4961-2745 FAX: (02) 4962-2812	THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRETANK SYSTEMS AND IS STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS Pty LIMITED
F				ADVANCED POWER			
E				DRAWN: V.B.B.	DATE: 10-9-03		
D				CHECKED:	DATE:	TITLE:	VESEL CLASS
C				APPROVED:	DATE:	GENERAL ARRANGEMENT	N/A
B	ITEM 9 ADDED	V.B.B.	10-9-03	ORDER No:	No OFF: ONE (1)	T5 ONGROUND STORAGE VESSEL	
A	ORIGINAL ISSUE	0	0	SCALE: N.T.S.	CAD REF: SA-Steel-AG	ESTIMATE NUMBER: N/A	SHEET SIZE
				Dimension in millimetres All tolerancing to be to the applicable design code of manufacture, and/or client requirement.		DRAWING NUMBER: SA 005000-004	
				JOB No:		SHEET: 1 of 1	REVISION: B
							A3