

# Single Wall & Double Wall

## Installation Checklist

### INSTALLATION SUPPLEMENT – TANK HANDLING DATA

Nominal Diameter mm	Nominal Capacity Litres	Single Wall Actual Capacity Litres	Single Wall Shipping Weight Kg	Double Wall Actual Capacity Litres	Double Wall Shipping Weight Kg	Length Overall mm
1470	2,000	2,500	150	2,400	300	1,700
1470	5,000	5,300	300	5,100	500	3,300
2600	10,000	13,500	900	13,200	1,300	3,295
2600	15,000	15,600	1,000	15,200	1,500	3,720
2600	20,000	21,800	1,300	21,300	1,900	4,995
2600	25,000	25,900	1,500	25,400	2,200	5,845
2600	30,000	30,000	1,700	29,500	2,500	6,695
2600	35,000	36,200	1,900	35,600	2,900	7,970
2600	40,000	40,300	2,100	39,700	3,200	8,820
2600	45,000	46,500	2,400	45,800	3,600	10,095
2600	50,000	50,600	2,600	49,800	3,900	10,945
2600	55,000	56,800	2,900	56,000	4,300	12,200
2600	60,000	60,900	3,100	60,000	4,600	13,070
3275	70,000	69,900	2,200	69,400	4,200	9,994
3275	80,000	79,800	2,600	79,200	4,700	11,254
3275	90,000	91,600	2,900	89,000	5,100	12,514
3275	100,000	102,000	3,100	102,000	5,600	14,194
3275	110,000	111,200	3,300	108,600	6,700	15,034

### INSTALLATION CHECKLIST:

#### Single Wall and Double Wall Underground Fibreglass Storage Tank(s)

The installing contractor must read the installation manual and complete and return this checklist within 30 days after the date of installation to validate the FTS warranty. The tank owner must retain a copy of this checklist and a copy of all deviation authorisations to substantiate any warranty claim.

Date of Installation \_\_\_\_\_ Tank size and capacity \_\_\_\_\_

Tank Type (Please Circle) [SW] [DW] - [SC] [DC] [TC] Tank Number \_\_\_\_\_

Site Owner \_\_\_\_\_

Site Address \_\_\_\_\_  
Street City State Postcode

Installing Contractor \_\_\_\_\_

Contractor Address \_\_\_\_\_  
Street City State Postcode

Supervisor On-Site \_\_\_\_\_

